



SECTION PIPE ABANDONMENT

NOTE:

1. PIPE PLUGS SHALL BE INSTALLED TO THE SATISFACTION OF THE ENGINEER.
2. ABANDONED PIPES, 12" AND LARGER, SHALL BE BROKEN INTO EVERY 50' AND SHALL BE FILLED COMPLETELY WITH SAND SLURRY.

DATE: 10/19/2023 SS-D DWG. NO. 24

SCALE: NOT TO SCALE

City of Hendersonville Engineering Department
 305 Williams Street
 Hendersonville, NC 28792
 (828) 697-3000 (office)

www.cityofhendersonville.org

PIPE ABANDONMENT

